

# ABHINAV ENGINEERING WORKS

W-85 [A], M.I.D.C. SATPUR, NASIK-422 007.

## INDEX

### INSPECTION DETAILS OF TESTING OF PRESSURE VESSELS / PRESSURE PLANTS

**Place of Inspection** M/s. Varroc Engineering Ltd (Plant - V),  
Plant - V, (Forging Division), Plot No.- L-6/2, M.I.D.C. Waluj,  
Aurangabad.

**Date Of Inspection**

**Name Of Competent Person** RAJENDRA PANDE

**Section Rule** Section 31 & Rule 65 of MFR 1963

Sr.No.	Name of Equipment / Plant	Safe Working Pressure	Ultrasonic Examination Date of Testing	Ultrasonic Next Due Date of Testing	Hydraulic Examination Date of Testing	Hydraulic Next Due Date of Testing	Observed Thickness
1	Air Pipe Line (Comp to Receiver), Equip. No.- 01., Location - Comp. to Air Receiver., Leangth - 4 Inch x 10 Meter (MS Pipe), Make - M/s. Local Fabricators. (HFD Compressor Room)	7.0 Kg/cm <sup>2</sup>	17-12-2024	16-06-2025	21-01-2025	20-01-2027	Not due
2	Air Pipe Line (Comp to Receiver), Equip. No.- 02., Location - Comp to Air Receiver. Leangth - 4 Inch x 50 Meter (MS Pipe), Make - M/s. Local Fabricators.	7.0 Kg/cm <sup>2</sup>	17-12-2024	16-06-2025	21-01-2025	20-01-2027	Not due
3	LPG Pipe Line, Equip. No.- 01, Location - LPG Yard to Hot Forging Compressor House, Length - 2 Inch x 100 Meter, Make - M/s. Local Fabricators.	7.0 Kg/cm <sup>2</sup>	17-12-2024	16-06-2025	21-01-2025	20-01-2027	Not due
4	Oil/Air Receiver Assy., Equip. No.- 12607/2012 (8315), Location - Comp. House Machine Shop-III No.2(21272449), Capacity - 185 Ltrs., Make - M/s. Inger Soll Rand	230 PSI	17-12-2024	16-06-2025	21-01-2025	20-01-2027	Not due
5	Moisture Separator Assy., Equip.No.-120682/09, Location-HFD Comp. Room, Cap.-60 Ltr., Make-Ingersoll Rand	16.0 Bar	17-12-2024	16-06-2025	21-01-2025	20-01-2027	Not due
6	LPG Pipe Line - 02, Location - Hot Forging Compressor House to Furnace, Lengths - 1 Inch x 100 Meter, Make - M/s. Localley	7.0 Kg/cm <sup>2</sup>	17-12-2024	16-06-2025	21-01-2025	20-01-2027	Not due

**For ABHINAV ENGINEERING WORKS**

**RAJENDRA PANDE**  
B.E. (Mech)  
COMPETENT PERSON  
C.P.C.NO. P-110/2023